

# 60140

Miniature Circuit Breaker Multi 9 (C60), 5A, 2-Pole, 240 Vac, 125 Vdc, HACR Rated



by Schneider Electric

List Price \$269.00 USD

Availability **Stock Item: This item is normally stocked in our distribution facility.**

## Technical Characteristics

|                              |  |
|------------------------------|--|
| Ampere Rating                | 5A   |
| General Application          | Short circuit and overcurrent protection                   |
| For Use With                 | OEM Panels and Enclosures                                  |
| Voltage Rating               | 240VAC - 125VDC  |
| Circuit Breaker Type         | Standard   |
| HACR Rated                   | Yes  |
| Terminal Type                | Line: Box Lug - Load: Box Lug                              |
| Mounting Type                | Flush, Surface or DIN Rail (35mm)                          |
| Weight                       | 8.70 Ounces  |
| Number of Poles              | 2-Pole   |
| Approvals                    | UL489 Listed - CSA 22.2 #5.1 Certified - IEC Rated 60947-2 |
| Enclosure Rating             | IP40   |
| Marketing Trade Name         | Multi 9  |
| Short Circuit Current Rating | 10kA@240VAC  |
| Type                         | C60N   |
| Wire Size                    | #18 to #4 AWG  |
| Depth                        | 3.00 Inches (76mm)   |
| Height                       | 4.21 Inches (107mm)  |
| Trip Curve                   | C Curve - Magnetic operates between 7 to 10 times          |
| Width                        | 1.42 Inches (36mm)   |

## Shipping and Ordering

|                   |   |
|-------------------|---|
| Category          | 00915 -   |
| Discount Schedule | DE2   |
| GTIN              | 00785901208617  |
| Package Quantity  | 1   |
| Weight            | 0.55 lbs.   |
| Availability Code | Stock Item: This item is normally stocked in our distribution facility. |
| Returnability     | Y   |
| Country of Origin | FR  |

As standards, specifications, and designs change from time to time, please ask for confirmation of the information given in this document.

Generated: 08/06/2012 06:56:52